

**Grand River Center Parking Garage Lighting Replacement  
Addendum #2**

**ADDITIONAL SCOPE:** Ten (10) existing junction boxes have been identified as once having lighting fixtures attached to them. Contractor shall replace and/or repair these boxes to comply with NEC and assure that circuits and wiring are maintained through the box at the completion of the project.

**REVISION:** REVISE one (1) TYPE DA-E to TYPE DA. No modifications to the existing emergency lighting circuiting are anticipated. Refer to the as-built drawings issued in Addendum #1 to verify this fixture location (middle of three PA-E added in Addendum #1).

**EXTENSION OF RFB CLOSURE:** Bids for this project will be accepted until Monday February 26, 2024 at 1:00 p.m. CST.



Jared M. Charland  
Project and Facilities Manager  
[jcharlan@cityofdubuque.org](mailto:jcharlan@cityofdubuque.org)  
563-690-6135